

# Outcomes of the 2008-2009 Compliance Tracking Report

## Outcomes

### 1. Sydney Water

Sydney Water was audited by the Sydney Water EMR, and assessed to be fully compliant with all relevant MCoA in 2008/2009

### 2. Blue Water Joint Venture

BWJV was audited by the Independent Verifier, SMEC, and assessed to be fully compliant with all relevant MCoA in 2008/2009

### 3. Water Delivery Alliance

WDA was audited by HS&E Risk Services Pty Ltd, and assessed to be compliant with the majority of relevant MCoA in 2008/2009. Non-compliance with one MCoA was identified.

The non-compliance was in relation to incidents of high turbidity, inconsistent with MCoA 2.19 - Desalinated Water Delivery System Project Approval.